



The **FIREMAN** Ltd

**TECHNICAL
LITERATURE**

Producer Statement


Date 11 / 07 / 11

The Kent Logfire fire installed for:

Mr/Mrs Jill Vincent

situated at 11 Sophia St

Building Consent # 67914



The above fire was installed according to the manufactures specifications and the Standard AS/NZS 2918:2001.

The following things were done during the installation:-

- ☐ Smoke alarms tested and locations checked (3m from each bedroom, and on the exit path)
- ☒ Flashing complies with E2
- ☒ Flue extends 600mm above the ridge if within 3m
- ☒ Seismic Restraints fitted
- ☒ Hearth measurement checked (Hearth Extension installed if too short)
- ☒ Flues sealed and fixed with 3 Stainless or Monel Fastners

Freestanding Installation

- ☐ Inner Liner used in ceiling and extending 200mm above roof penetration
- ☐ Support Stays installed if flue extends more than 1500mm from penetration

Insert installation

- ☒ All cracks in masonry cavity filled with fire resistant sealant or matting
- ☒ Chimney swept
- ☐ No exposed timber in cavity
- ☒ Mantle height checked (Mantle reflector installed if too low)

NZHHA Certified Installer



RRD001JKBJ

Document Number: **RDC-209576**

Date Registered: **22/08/2011**

Certified Fire Installer (NZHHA)

Phone: 0800 FIREMAN
(347 362)

Showroom: 54 Hewletts Road
Mount Maunganui

Address: PO Box 11446
Papamoa

"Keeping you Warm"