



# Compliance and Electrical Safety Certificate

This form has been issued by the Electrical Workers Registration Board



Unique ID: SRE0158

This form has been designed to be used by licensed electrical workers to certify low voltage installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

## (1) Location of installation

Address: 9A Manning St Rawene

## (2) Customer Information

Name: Peter Wilson

Postal Address: 9A Manning St Rawene

Phone and Email: 0221724125

## (3) Electrical Worker Information

Name: Shane Richardson

Registration/Practising Licence Number: E12192

Organisation: Shane Richardson Electrical Limited

Telephone Number: 0274525295

Email: srelectrical@xtra.co.nz

Name of person(s) being supervised: \_\_\_\_\_

## (4) Work Details

The work is (circle): ☐ additions ☒ alterations ☒ new work

The prescribed electrical work is:  
(Please tick (✓) as appropriate)

☐ High Risk

☒ General

☐ Low Risk

☐ The homeowner has undertaken part of the electrical installation work.

Indicate the number of each item installed or altered:

Number of lighting outlets: 27

Number of socket outlets: 35

Number of ranges: 1

Number of water heaters: \_\_\_\_\_

### Other Work?

Rewire of house. Upgrade of switch board to earth leakage breakers and circuit breakers. All power and light circuits including downstairs unit.

Tick (✓) if work includes:

☐ Mains

☒ MEN switchboard closest to point of supply

☐ Main Earthing System

☐ Electric Lines

## (5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- ☐ has been installed in accordance with a certified design
- ☒ has an earthing system that is correctly rated
- ☒ contains fittings which are safe to connect to a power supply
- ☒ relies on supplier's Declaration of Conformity (attach or reference<sup>1</sup>)
- ☒ relies on manufacturer's instructions (attach or reference<sup>1</sup>)
- ☒ has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- ☒ is safe to connect

Electronic reference: SRE0158

Electrical Worker's Signature: SR

Date: 23/11/2023

1. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

Test Results:		
	Electrical Worker	Inspector
Polarity (independent earth):	O.K	
Insulation resistance:	>200	
Earth continuity:	<0.5	
Bonding:	<0.5	
Other (specify):		

## (6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

Name: Shane Richardson

Registration/Practising Licence Number: E12192

Signature: SR

(if certifier is different from electrical worker)

Date: 23/11/2023



# Compliance and Electrical Safety Certificate

This form has been issued by the Electrical Workers Registration Board



Safety • Competency

Unique ID: SRE0159

This form has been designed to be used by licensed electrical workers to certify low voltage installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

## (1) Location of installation

Address: 9B Manning St Rawene

## (2) Customer Information

Name: Peter Wilson

Postal Address: 9B Manning St Rawene

Phone and Email: 0221724125

## (3) Electrical Worker Information

Name: Shane Richardson

Registration/Practising Licence Number: E12192

Organisation: Shane Richardson Electrical Limited

Telephone Number: 0274525295

Email: srelectrical@xtra.co.nz

Name of person(s) being supervised:

## (4) Work Details

The work is (circle): ☐ additions ☒ alterations ☒ new work

The prescribed electrical work is:  
(Please tick (✓) as appropriate)

☐ High Risk

☒ General

☐ Low Risk

☐ The homeowner has undertaken part of the electrical installation work.

Indicate the number of each item installed or altered:

Number of lighting outlets: 27

Number of socket outlets: 30

Number of ranges: 1

Number of water heaters:

### Other Work?

Rewire of house. Upgrade of switch board to earth leakage breakers and circuit breakers. All power and light circuits including downstairs unit.

Tick (✓) if work includes:

☐ Mains

☒ MEN switchboard closest to point of supply

☐ Main Earthing System

☐ Electric Lines

## (5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- ☐ has been installed in accordance with a certified design
- ☒ has an earthing system that is correctly rated
- ☒ contains fittings which are safe to connect to a power supply
- ☒ relies on supplier's Declaration of Conformity (attach or reference<sup>1</sup>)
- ☒ relies on manufacturer's instructions (attach or reference<sup>1</sup>)
- ☒ has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- ☒ is safe to connect

Electronic reference: SRE0159

Electrical Worker's Signature:

Date: 23/11/2023

1. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

Test Results:		
	Electrical Worker	Inspector
Polarity (independent earth):	O.K	
Insulation resistance:	>200	
Earth continuity:	<0.5	
Bonding:	<0.5	
Other (specify):		

## (6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

Name: Shane Richardson

Registration/Practising Licence Number: E12192

Signature:

Date: 23/11/2023

(if certifier is different from electrical worker)