

RODNEY DISTRICT COUNCIL

BUILDING SECTION

FINAL INSPECTION

TO BE ACTIONED AS BELOW (Delete not required)

CODE COMPLIANCE CERTIFICATE

BUILDING CONSENT REFUND

TEAM LEADER BUILDING COMPLIANCE

COMPLIANCE SCHEDULE

OTHER:

Signed:  Date: 28.8.03.

Checked:  Date: 29.8.03.

(Team Leader Building Compliance)

2
1@ 60
1@ 75

APPLICATION NUMBER 981097

OFFICER COMMENTS

Date	Comments
18.5.98	St₂ cables accepted. #21-6 - effluent report & Pot. contaminated site. WJ

Date Inspected

20/12/99

Sited ok
Footings

ALL HOLES ARE DUE TO SIZE AND DEPTH REQUIRED AS PER PLAN INTO GOOD GRAVEL. SOME WATER IN HOLES. THE BUILDER WAS TOLD TO CLEAN OUT WATER AND MAKE SURE WHERE CLEAN BEFORE POURING. OK TO POUR WHEN CLEAN. mhl.

28/8/03

Final: Two sheds as detailed structurally formed to cross-section details, with additional bracing and supporting cleats under rafters. Purlins have been 2 nailed or wired to rafters. Bolt & washers in place to details along with joist hanger connections to rafters, well nailed. Stormwater from both roofs piped to separate storage tanks with overflows to creek.

B.H.

CODE COMPLIANCE CERTIFICATE

Certifier	Signature	Date	Certifier	Signature	Date
BUILDING	<i>B. Hill</i>	<i>28-8-03</i>	POWER		
PLUMBING			GAS		
DRAINAGE			SERVICES		
E.H.O.			RESOURCE MGMT		
LIFTS			AIR COND.		
OTHER					

WORK IS NOW DEEMED TO BE COMPLETED. A CODE COMPLIANCE CERTIFICATE WILL BE ISSUED AS REQUIRED BY THE BUILDING ACT. CODE COMPLIANCE CERTIFICATE NO. _____

[Signature]
Signature

B. F. O
Designation

28/8/03
Date

WHEN THIS PROJECT IS COMPLETED THIS INSPECTION SHEET WILL BE ATTACHED TO THE RELEVANT PROPERTY FILE HELD AT THE COUNCIL OFFICE.

SPECIAL CONDITIONS: