



Electrical Workers Registration Board

SAFETY | COMPETENCY | COMPLIANCE

RECEIVED

13 JUL 2018

AUCKLAND COUNCIL

Electrical Certificate of Compliance

Reference/Certificate ID No: 7113



This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under **Part 1 or Part 2 of AS/NZS 3000** are safe to be connected to the **specified** system of electrical supply.

LOCATION AND CONTACT

Location Details Matakana Valley Road

Contact Name Matakana Sawmill Ltd

Name of Electrical worker: Steven Grimmer

Organisation/ company: Davco Electrical Services Ltd

Phone: 09 425 8339

Name of person(s) supervised:

Contact Address 362 Matakana Valley Road, Warkworth, ,
Warkworth Postcode

Registration/Practising E246206
licence number:

Email: admin@davcoelectrical.co.nz

CoC

- Type of work: ☐ Additions ☐ Alterations ☒ New work
- The prescribed electrical work is: ☐ Low risk ☐ General ☒ High risk (specify):
- Reference Standards: ☐ Part 1 of AS/NZS 3000 ☐ Part 2 of AS/NZS 3000
- ☐ Additional Standards:

Description of work: (including date/s of work and type of supply system)

Install 2 new distribution boards feed off existing montrose. Install 15 hlbay led fittings 13 downlights in office and toilet. 8 socket outlets in office and toilet. One socket outlet on each distribution board. Install emergency lights as per emergency light plan.

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct in that the installation, or part of the installation:

Select those that apply:

- ✓ Has been installed in accordance with the specified certified design¹
- ✓ Has an earthing system that is correctly rated (where applicable)
- ✓ Contains fittings that are safe to connect to a power supply
- ✓ Relies on a supplier Declaration of Conformity¹
- ✓ Has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010
- ✓ Is safe to connect

Electronic/Other reference:

Steven Grimmer

Certifier's signature:

Test Results

Polarity (independent earth):	Ok
Insulation resistance:	200m ohm
Earth Continuity:	Ok
Bonding:	
Fault Loop impedance:	0.40 outlets
Other (specify):	Rcd 28ms

Date: 26/06/2018

¹ Attach or reference. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declaration of conformity, provide a reference to where the documents can be found, in a readily accessible format, by electronic means.

Notes

CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS

This certificate also confirms that the electrical work complies with the building code for the purposes of Section 19(1)(e) of the Building Act 2004.