

2 July 2007

Brian Morrison & Vanessa Morris on Family Trust
1334 Sandspit Road
R D 2 Warkworth 1241

Attention: Brian Morrison

Dear Sir

RESOURCE CONSENT

Consent Details:

File Ref: 7835

Consent Number:	22315
Consent Holder:	Brian Morrison & Vanessa Morris on Family Trust (Brian Phillip Morrison & Vanessa Anne Morrison)
Site Name:	
Activity Type:	Wastewater Discharge
Location:	Sandspit Road Sandspit Rodney District
Expiry Date:	30 June 2014

Thank you for submitting your sample results for February.

The sample results showed high levels of faecal coliforms. This may indicate a decline in the performance of your wastewater treatment system and may pose a health hazard. Please contact your maintenance supplier or consultant to investigate the system and report the investigation results back to the Auckland Regional Council (ARC).

This information should be returned to the ARC, marked to the attention of the undersigned by **23 July 2007**. If information is not available by this date, please contact me to discuss an alternative.

Also below is a list of the information that you are required to submit on an ongoing basis. Please refer to your consent document for further details.

Please note that as the ARC is a ratepayer funded organisation, it is our policy to recover costs incurred while dealing with non-compliance with a resource consent from the consent holder. Failure to provide the information requested by the due date may result in cost recovery following resolution of the matters.

If you have any queries regarding your consent, please contact me on 3662000 ext. 8652 and quote the consent number above.

Yours faithfully

Sarah McCarter
Consents and Compliance Officer
Consents and Consents Compliance

Compliance Information Required by ARC

Sewage Discharge

You are required to submit information to ARC on an ongoing basis. This information is summarised below (again please refer to the consent document for further details):

Self Monitoring:

Consent Condition	Information Required	Date Required
19	Flow records 25cmpd, daily 1 Dec-28 Feb, 1st day of month 1 Mar-30 Nov	Quarterly
22	Sampling requirements (effluent sample, suspended solids, faecal coliforms, and enterococci analysis). Standard: Suspended solids (less than 20 mg/l) - Quarterly	Quarterly
17	Complaints & Emergencies records	As required

**Please forward the required information to the ARC,
Private Bag 92012, Auckland, by 1 March, 1 June, 1
September and 1 December each year, marked to the
attention of your Compliance Monitoring Officer.**

2003 ACHIEVEMENT AWARD WINNER



"The Catalyst for Performance and Results"