


GoGet Inspection Outcome Report

Consent No: **20172013**
Applicant: **Spaghetti Junction Limited**
Site Address: **80 Byron Street Sydenham**
Legal Description: **Lot 1 DP 449853**
Work Type: **Addition to Factory - New Offices, Meeting and Store Room**
Workgroup: **Area 4 - Residential**

Inspection Type: **210 - Commercial - Final**
Inspection Outcome: **Pass**
Inspected By: **Brian Abrahams**
Inspection Date: **11 May 2020 1:26 p.m.**
Duration: **30 minutes**

Inspection Element	Status
COVID-19 (Level 3)	N/A
SUMMARY	Pass
Inspection outcome	Pass
Summary of inspection undertaken:	Pass
Observation:	
1. Kerb & channel completed.	
2. ISA signage installed @ main entry.	
3. UV protection installed @ lagging @ gas mixer.	
4. Soffit sealed.	
5. Owner's written approval received for change in building paper as requested in 253 inspection.	
6. Backflow prevention device installed.	
GENERAL	Pass
Who attended:	Pass
desktop inspection	
ACCESSIBILITY	Pass
Int. Symbol of Access (ISA)	Pass
ISA symbols installed as per F8/AS1	
BUILDING	Pass
Signage	Pass
Escape route signage	
Accessible routes and facilities for persons with disabilities - (ISA)	
Barriers, Handrails & Stairs:	N/A
Plumbing & Drainage	Pass
Surface water drainage complete	
HISTORIC CONSENTS	N/A



BFPD installed

Taken at 1:24 PM on Monday 11/05/2020



Kerb installed

Taken at 1:24 PM on Monday 11/05/2020




Soffits sealed

Taken at 1:25 PM on Monday 11/05/2020



ISA sign installed

Taken at 1:25 PM on Monday 11/05/2020



UV protection installed @ lagging @ gas mixer
Taken at 1:25 PM on Monday 11/05/2020