

13-Feb-2007

Ref: ABA-31972

Dean Gordon Munro
P O Box 142
Matakana
Warkworth 1241

INSPECTION - BUILDING CONSENT NO: ABA-31972
Location 2-6 Wharf Street, Warkworth 1241

An inspection of the building work authorised by the issue of the above consent was carried out on 12.02.07. The items listed below require attention:

ITEMS TO BE COMPLETED

- 1) Weather proof joints. Sealant is not acceptable as a joint sealer without additional protection from U V rays. Install propriety PVC joiner or cover with a timber moulding with drip groves

We reserve the right to issue any further requisitions as may be required to bring this consent to a satisfactory conclusion.

Please request a final inspection (recheck) on completion of the above item/s.

Yours faithfully

Ron Smith
Building Field Officer
BUILDING AND DEVELOPMENT CONTROL