

23 July 2021

Morel Construction Limited
PO Box 35270
Shirley
Christchurch 8640

Dear Sir/Madam

Code compliance certificate application – request for information

BCN/2017/2013
80 Byron Street Sydenham
Addition to Factory - New Offices, Meeting and Store Room

We have received your code compliance certificate application for the above building consent.

We need more information to make sure your building work complies with your approved building consent documents.

The information we need is:

- **Penetrations through fire separations:** Producer statement for construction (PS3) from the nominated contractor. – Is there any services that carried out sealing to penetrations on this project? ie; holes made by plumber, electrician etc. through fire walls.
- **Emergency lighting;** the supplied EML PS4 needs to be amended to include amendment number BCN/2017/2013/B, please contact your emergency lighting design consultant to revise it.

Can you please send us this information as soon as possible, as your application is now on hold. If we don't hear from you soon we may have to refuse the application under the Building Act 2004.

You can send us the information we have asked for by replying to this email. If you would like to talk to us, you can call the number below.

Please do not lock or password-protect PDFs, as we need to merge them into final consent documents.

This letter is sent to the applicant and the owner, where possible.

Yours sincerely



Weiwei Xia
Code Compliance Assessor
03 941 8478